

Regional Communications System
Network Incident Log
March 1999

9335 Hazard Way, #105
San Diego, CA 92123
Tel. (619) 694-3663
Fax (619) 694-3433
Web Site: <http://www.co.san-diego.ca.us/rcs>

●	Scheduled Maintenance
⚡	Unscheduled Maintenance
▼	System Outage

	Date Time	System(s) Impacted	Incident Summary
?	03-02 1000-1100	North Simulcast (Lake San Marcos Peak)	Connections made to controller to provide remote "failsoft" indications. Information only.
?	03-12 1100-1700	Carlsbad and Rancho Santa Fe Dispatch Microwave	Preventative maintenance of the microwave. Information only.
?	03-23 0800-1600	Monument/Pinos	Trouble shooting microwave for problem. Replaced the defective module. Information only.
?	03-30 1030-1500	RCS Site 314-Campo	Added a fourth voice channel site. Reduced coverage around Campo for a brief period.
▼	03-31 1520-1532 12 minutes	Superstition Mountain	Commercial electrical power failure. Generator was not functional because it was being repaired. Loss of radio trunking.
▼	03-31 1400-1600	Birch Hill	Intermittent microwave link failure. Dish antenna blew on and off alignment to Sierra Rojo due to high gusty winds. Staff realigned and secured mounting hardware. In and out of wide area trunking for 2 hours.